



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Hanumangarh

Report of the Chemical Examination of Water

Run No. 405, Date: 20/06/2025

To:
Assistant Engineer,
Sub Division, Tonk,
Raj.

358
24/06/25

Page 1 of 1

Dist. Lab. Hanumangarh
Raj.

Sample No.	Gram Panchayat	Village/Town	Habitation	Source Name	Location	Collection Date	Date of Examination	pH	Acidity	Total Hardness	Calcium	Magnesium	Chloride	Sulfate	Fluoride	Total
370	MIRJEWALI MED	13 AG	13 AG	CWR	Head Works	20/06/2025	21/06/2025	7.4	140	170	41	14.64	90	4	0.45	185
380	CHAHUWALI	10 AG	10 AG	CWR	Head Works	20/06/2025	23/06/2025	7.8	130	150	32	24.4	80	5	0.42	157
381	CHAHUWALI	11 RWD	11 RWD	CWR	Head Works	20/06/2025	23/06/2025	7.65	170	250	76	17.08	120	20	1.0	1100
382	TIBI	8 GGR	8 GGR	TW	MDAV Public School T-10	20/06/2025	23/06/2025	7.85	110	320	92	21.98	90	14	0.58	750
383	MIRJEWALI MED	12 AG	12 AG	TW	Head Works RWSS	20/06/2025	23/06/2025	7.6	100	120	24	14.64	20	4	0.35	201
384	MALAR KHEDA	3 DPM	3 DPM	CWR	Head Works	20/06/2025	23/06/2025	7.7	150	200	72	26.84	100	9	0.75	78


सहायक अभियन्ता
जन स्वा. अभि. विभाग
उपखण्ड टिब्बी


District Laboratory, Hanumangarh

Note: All Results Except pH are in mg/l
Reference: Water & Power (Pollution) (U)
Circular: 26/2025 26/2025 184